22.04.2022 / All data subject to change.

## Selection: Semi-hermetic Reciprocating Compressors

#### Input Values

conditioning

Refrigerant R404A Power supply 400V-3-50Hz
Reference temperature Dew point temp. Capacity control 100%
Liq. subc. (in condenser) 0 K Useful superheat 100%

Result

 Q [W]
 Cooling capacity
 COP [ - ]
 COP/EER

 Qu\* [W]
 Evaporator capacity
 m [kg/h]
 Mass flow

 P [kW]
 Power input
 Op.
 Operating mode

 $\label{eq:localization} I\,[A] \qquad \qquad \text{Current} \qquad \qquad \text{th}\, [^\circ\text{C}] \qquad \qquad \text{Discharge gas temp. w/o cooling}$ 

Qc [W] Condenser capacity

tc	to	0°C	-5°C	-10°C	-15°C	-20°C	-25°C	-30°C	-35°C
30°C	Q [W]	119989	99886	82444	67348	54331	43157	33619	25530
	Qu* [W]	119989	99886	82444	67348	54331	43157	33619	25530
	P [kW]	28,6	27,2	25,6	23,8	21,8	19,74	17,56	15,28
	I [A]	53,2	51,2	49,1	46,8	44,3	41,8	39,2	36,8
	Qc [W]	148636	127079	108002	91107	76144	62897	51175	40810
	COP [ - ]	4,19	3,67	3,23	2,83	2,49	2,19	1,91	1,67
	m [kg/h]	3050	2509	2051	1661	1331	1051	814	616
	Ор.	Standard	Standard	Standard	Standard	Standard	Standard	Standard	Standard
	th [°C]	65,1	71,4	78,0	85,2	93,1	101,8	111,7	122,9
40°C	Q [W] Qu* [W]	102614 102614	85353 85353	70324 70324	57276 57276	45993 45993	36283 36283	27973 27973	20907 20907
	P [kW]	32,7	30,6	28,4	26,0	23,5	21,0	18,29	15,57
	I [A]	58,6	55,8	52,8	49,7	46,5	43,3	40,1	37,1
	Qc [W]	135300	115960	98700	83288	69524	57234	46264	36474
	COP [ - ]	3,14	2,79	2,48	2,20	1,95	1,73	1,53	1,34
	m [kg/h]	2944	2416	1969	1588	1265	992	760	566
	Ор.	Standard	Standard	Standard	Standard	Standard	Standard	Standard	Standard
	th [°C]	75,4	81,7	88,5	95,8	103,8	112,8	122,8	134,5
50°C	Q [W] Qu* [W]	85319 85319	70915 70915	58311 58311	47323 47323	37785 37785	29548 29548	22476 22476	16441 16441
	P [kW]	36,4	33,7	30,9	28,0	25,0	21,9	18,78	15,63
	I [A]	63,7	60,0	56,2	52,3	48,4	44,4	40,7	37,1
	Qc [W]	121728	104632	89215	75309	62767	51457	41261	32069
	COP [ - ]	2,34	2,10	1,89	1,69	1,51	1,35	1,20	1,05
	m [kg/h]	2842	2326	1888	1516	1199	931	703	512
	[9,]								
	Op.	Standard	Standard	Standard	Standard	Standard	Standard	Standard	Standard


<sup>--</sup> No calculation possible (see message in single point selection)

## Application Limits 100% 6G-40.2

1/6

<sup>\*</sup>According to EN12900 (20°C suction gas temp., 0K liquid subcooling)








# Technical Data: (6G-40.2Y)

#### **Dimensions and Connections**



#### **Technical Data**

_	ach		

Displacement (1450 RPM 50Hz) 126,8 m³/h Displacement (1750 RPM 60Hz) 153,0 m³/h

No. of cylinder x bore x stroke 6 x 75 mm x 55 mm

Weight 238 kg
Max. pressure (LP/HP) 19 / 28 bar
Connection suction line 54 mm - 2 1/8"
Connection discharge line 35 mm - 1 3/8"

Connection cooling water R 3/4"

Oil type R134a/R407C/R404A/R507A/R407A/R407F tc<55°C: BSE32 | tc>55°C: BSE55 (Option)

Oil type R22 (R12/R502) B5.2 (Standard)
Oil type R290/R1270 SHC226E (Standard)

Motor data

Motor voltage (more on request) 380-420V PW-3-50Hz

Max operating current 78.0 A Winding ratio 50/50

Starting current (Rotor locked) 180.0 A Y / 323.0 A YY

Max. Power input 45,1 kW

Extent of delivery (Standard)

Motor protection SE-B2

Enclosure class IP54 (Standard), IP66 (Option)

Vibration dampers Standard
Oil charge 4.75 dm³

**Available Options** 

Connection suction line Option
Discharge shut-off valve Option
Discharge gas temperature sensor Option
Start unloading Option

Capacity control 100-66-33% (Option)

Additional fan Option
Water-cooled cylinder heads Option
Oil service valve Option

Crankcase heater 140 W (Option)

Oil pressure monitoring MP54 (Option), Delta-PII (Option, not for R290/R1270)

Sound measurement



22.04.2022 / All data subject to change.

4/6

Sound pressure level @ 1m (-10°C / 45°C) 75,5 dB(A) @ 50Hz Sound pressure level @ 1m (-35°C / 40°C) (82,5) dB(A) @ 50Hz



22.04.2022 / All data subject to change

## Semi-hermetic Reciprocating Compressors

**Motor 1 =** e.g. 4TES-12 with 12"HP", primary for air-conditioning (e.g. R22,R407C) and air-conditioning with R134a at high ambient temperatures.

**Motor 2 =** e.g. 4TES-9 with 8"HP", universal Motor for medium and low temperature application (e.g. R404A, R507A, R407A, R407F) and air-conditioning with R134a

Motor 3 = e.g. 4TES-8, for medium temperature applications and R134a

For more information concerning the application range use the "Limits" button.

#### Operation modes 4VES-7 to 6FE-44 and 44JE-30 to 66FE-88 with R407F/R407A/R22

CIC = liquid injection with low temperature application, suction gas cooled motor.

### ASERCOM certified performance data

The Association of European Refrigeration Component Manufacturers has implemented a procedure of certifying performance data. The high standard of these certifications is assured by:

- \* plausibility tests of the data performed by experts.
- \* regular measurements at independent institutes.

These high efforts result in the fact that only a limited number of compressors can be submitted. Due to this not all BITZER compresors are certified until now. Performance data of compressors which fulfil the strict requirements may carry the label "ASERCOM certified". In this software you will find the label at the respective compressors on the right side below the field "result" or in the print out of the performance data. All certified compressors and further information are listed on the homepage of ASERCOM.

#### Condensing capacity

The condensing capacity can be calculated with or without heat rejection. This option can be set in the menu Program  $\square$  Options. The heat rejection is constantly 5% of the power consumption. The condensing capacity is to be found in the line Condensing cap. (with HR) resp. Condensing capacity.

#### Data for sound emission

Data based on 50 HZ apllication (IP-units 60 Hz) and R404A if not declared.

Sound pressure level: values based on free field area conditions with hemisperhical sound emission in 1 meter distance.

#### General remarks regarding sound data

Listed sound data were measured under testing conditions in our laboratory. For this purpose the free-standing test sample is mounted on a solid foundation plate and the pipework is connected vibration-free to the largest extend possible. Suction and discharge lines are fixed in a flexible configuration, such that a transmission of vibrations to the environment can be largely excluded. In real installations considerable differences might be observed, compared to the measurements in the laboratory. The airborne sound emitted by the compressor can be reflected from surfaces of the system and this may increase the airborne sound level measured close to the compressor. Vibrations caused by the compressor are also transferred to the system by the compressor feet and piping depending on the damping ratio of the fixings. Thus, the vibrations can induce other components to such an extent that these components contribute to an increase in airborne sound emission. If required, the transfer of vibrations to the system can be minimized by suitable fixing and damping elements.

#### Legend of connection positions according to "Dimensions":

- 1 High pressure connection (HP)
- 2 Connection for discharge gas temperature sensor (HP) (for 4VE(S)-6Y .. 4NE(S)-20(Y) connection for CIC sensor as alternative)
- 3 Low pressure connection (LP)
- 4 CIC system: injection nozzle (LP)
- 4b Connection for CIC sensor
- 4c Connection for CIC sensor (MP / operation with liquid subcooler)
- 5 Oil fill plug
- 6 Oil drain
- 7 Oil filter (magnetic screw)
- 8 Oil return (oil separator)
- 8\* Oil return with NH3 and insoluble oil
- 9 Connection for oil and gas equalization (parallel operation)
- 9a Connection for gas equalization (parallel operation)

5/6



22.04.2022 / All data subject to change.

6/6

- 9b Connection for oil equalization (parallel operation)
- 10 Oil heater connection
- 11 Oil pressure connection +
- 12 Oil pressure connection -
- 13 Cooling water connection
- 14 Intermediate pressure connection (MP)
- 15 Liquid injection (operation without liquid subcooler and with thermostatic expansion valve)
- 16 Connection for oil monitoring (opto-electrical oil monitoring "OLC-K1" or differential oil pressure switch "Delta-PII")
- 17 Refrigerant inlet at liquid subcooler
- 18 Referigerant outlet at liquid subcooler
- 19 Clamp space
- 20 Terminal plate
- 21 Maintenance connection for oil valve
- 22 Pressure relief valve to the atmosphere (discharge side)
- 23 Pressure relief valve to the atmosphere (suction side)
- 24 IQ MODULE
- SL Suction gas line
- DL Discharge gas line

Dimensions can show tolerances according to EN ISO 13920-B.