

# Selection: Semi-hermetic Reciprocating Compressors

#### Input Values


Compressor model Mode		(4KTC-10K) Refrigeration and Air conditioning	Suct. gas superheat Operating mode		10,00 K Transcritical	
Refrigerant Reference temperature Gas cooling outlet <b>Result</b>		R744 Dew point temp. 25,0 °C	Power supply Capacity control Useful superheat		400V-3-50Hz 100% 100%	
Q [W] Qu* [W] P [kW] I [A] Qc [W]	Cooling capacity Evaporator capacity Power input Current Condenser capacity		COP [ - ] m [kg/h] Op. th [°C]	COP/EER Mass flow Operating mode Discharge gas temp.	w/o cooling	

Pc	to	10°C	5°C	0°C	-5°C	-10°C	-15°C	-20°C	-25°C
80bar(a)	Q [W]			34911	29239	24163	19704	15869	
	Qu* [W]			34911	29239	24163	19704	15869	
	P [kW]			10,06	10,12	9,99	9,68	9,20	
	I [A]			17,00	17,09	16,90	16,44	15,74	
	Qc [W]			44970	39362	34156	29386	25071	
	COP [ - ]			3,47	2,89	2,42	2,04	1,72	
	m [kg/h]			682	568	468	381	307	
	Op.			Transcritical	Transcritical	Transcritical	Transcritical	Transcritical	
	th [°C]			86,0	94,6	104,6	116,1	129,2	
90bar(a)	Q [W]			34026	28437	23424	19007	15190	
	Qu* [W]			34026	28437	23424	19007	15190	
	P [kW]			11,42	11,29	10,97	10,48	9,83	
	I [A]			19,03	18,83	18,35	17,62	16,66	
	Qc [W]			45447	39723	34391	29484	25019	
	COP [ - ]			2,98	2,52	2,14	1,81	1,55	
	m [kg/h]			651	541	444	360	288	
	Op.			Transcritical	Transcritical	Transcritical	Transcritical	Transcritical	
	th [°C]			98,9	108,2	119,0	131,5	145,9	
100bar(a)	Q [W]			32961	27492	22575	18228		
	Qu* [W]			32961	27492	22575	18228		
	P [kW]			12,66	12,33	11,84	11,18		
	I [A]			20,9	20,4	19,66	18,67		
	Qc [W]			45617	39826	34413	29408		
	COP [ - ]			2,60	2,23	1,91	1,63		
	m [kg/h]			621	515	422	340		
	Op.			Transcritical	Transcritical	Transcritical	Transcritical		
	th [°C]			111,3	121,3	132,9	146,6		

-- No calculation possible (see message in single point selection)

\*according to EN12900 (10K suction gas superheat)

## Application Limits 100% 4KTC-10K






12 30.05.2023 / All data subject to change.

3/6

# Technical Data: (4KTC-10K)

# **Dimensions and Connections**





#### **Technical Data**

Technical Data					
Displacement (1450 RPM 50Hz)	9,6 m3/h				
Displacement (1750 RPM 60Hz)	11,58 m3/h				
No. of cylinder x bore x stroke	4 x 36mm x 27mm				
Weight	108 kg				
Max. pressure (LP/HP)	100/160 bar				
Connection suction line	22 mm - 7/8"				
Connection discharge line	18 mm - 3/4"				
Oil type R744 (CO2)	BSE85K (Standard)				
Motor data					
Motor version	2				
Motor voltage (more on request)	380-420V Y-3-50Hz				
Max operating current	22.4 A				
Starting current (Rotor locked)	97.0 A				
Max. Power input	12,9 kW				
Extent of delivery (Standard)					
Motor protection	SE-B3(Standard), SE-B2(Option)				
Enclosure class	IP65				
Vibration dampers	Standard				
Oil charge	2,00 dm <sup>3</sup>				
Crankcase heater	0120 W PTC (Standard)				
Available Options					
Connection suction line	Option				
Discharge shut-off valve	Option				
Oil level monitoring	OLC-K1 (Option)				
Sound measurement					
Sound power level (-10°C / 90bar)	82 dB(A) @ 50Hz				
Sound pressure level @ 1m (-10°C / 90bar)	74 dB(A) @ 50Hz				



BITZER Software v6.18.0 rev2812 30.05.2023 / All data subject to change

5/6

# Semi-hermetic Reciprocating Compressors

**Motor 1 =** e.g. 4TES-12 with 12"HP", primary for air-conditioning (e.g. R22,R407C) and air-conditioning with R134a at high ambient temperatures.

**Motor 2 =** e.g. 4TES-9 with 8"HP", universal Motor for medium and low temperature application (e.g. R404A, R507A, R407A, R407F) and air-conditioning with R134a

Motor 3 = e.g. 4TES-8, for medium temperature applications and R134a

For more information concerning the application range use the "Limits" button.

## Operation modes 4VES-7 to 6FE-44 and 44JE-30 to 66FE-88 with R407F/R407A/R22

CIC = liquid injection with low temperature application, suction gas cooled motor.

## ASERCOM certified performance data

The Association of European Refrigeration Component Manufacturers has implemented a procedure of certifying performance data. The high standard of these certifications is assured by:

\* plausibility tests of the data performed by experts.

\* regular measurements at independent institutes.

These high efforts result in the fact that only a limited number of compressors can be submitted. Due to this not all BITZER compresors are certified until now. Performance data of compressors which fulfil the strict requirements may carry the label "ASERCOM certified". In this software you will find the label at the respective compressors on the right side below the field "result" or in the print out of the performance data. All certified compressors and further information are listed on the homepage of ASERCOM.

#### Condensing capacity

The condensing capacity can be calculated with or without heat rejection. This option can be set in the menu Program 
Options. The heat rejection is constantly 5% of the power consumption. The condensing capacity is to be found in the line Condensing cap. (with HR) resp. Condensing capacity.

#### Data for sound emission

Data based on 50 HZ apllication (IP-units 60 Hz) and R404A if not declared. Sound pressure level: values based on free field area conditions with hemisperhical sound emission in 1 meter distance.

#### General remarks regarding sound data

Listed sound data were measured under testing conditions in our laboratory. For this purpose the free-standing test sample is mounted on a solid foundation plate and the pipework is connected vibration-free to the largest extend possible. Suction and discharge lines are fixed in a flexible configuration, such that a transmission of vibrations to the environment can be largely excluded. In real installations considerable differences might be observed, compared to the measurements in the laboratory. The airborne sound emitted by the compressor can be reflected from surfaces of the system and this may increase the airborne sound level measured close to the compressor. Vibrations caused by the compressor are also transferred to the system by the compressor feet and piping depending on the damping ratio of the fixings. Thus, the vibrations can induce other components to such an extent that these components contribute to an increase in airborne sound emission. If required, the transfer of vibrations to the system can be minimized by suitable fixing and damping elements.

#### Legend of connection positions according to "Dimensions":

1 High pressure connection (HP)
2 Connection for discharge gas temperature sensor (HP) (for 4VE(S)-6Y .. 4NE(S)-20(Y) connection for CIC sensor as alternative)
3 Low pressure connection (LP)
4 CIC system: injection nozzle (LP)
4b Connection for CIC sensor
4c Connection for CIC sensor (MP / operation with liquid subcooler)
5 Oil fill plug
6 Oil drain
7 Oil filter (magnetic screw)
8 Oil return (oil separator)
8\* Oil return with NH3 and insoluble oil
9 Connection for oil and gas equalization (parallel operation)
9a Connection for gas equalization (parallel operation)



#### BITZER Software v6.18.0 rev2812 30.05.2023 / All data subject to change.

9b Connection for oil equalization (parallel operation)

- 10 Oil heater connection
- 11 Oil pressure connection +
- 12 Oil pressure connection -
- 13 Cooling water connection
- 14 Intermediate pressure connection (MP)
- 15 Liquid injection (operation without liquid subcooler and with thermostatic expansion valve)
- 16 Connection for oil monitoring (opto-electrical oil monitoring "OLC-K1" or differential oil pressure switch "Delta-PII")
- 17 Refrigerant inlet at liquid subcooler
- 18 Referigerant outlet at liquid subcooler
- 19 Clamp space
- 20 Terminal plate
- 21 Maintenance connection for oil valve
- 22 Pressure relief valve to the atmosphere (discharge side)
- 23 Pressure relief valve to the atmosphere (suction side)
- 24 IQ MODULE
- SL Suction gas line
- DL Discharge gas line

Dimensions can show tolerances according to EN ISO 13920-B.