31.05.2023 / All data subject to change.

Selection: Semi-hermetic Reciprocating Compressors

Input Values

Compressor model (4VCS-6.2Y) Suction gas temperature 20,00 °C Mode Refrigeration and Air Operating mode Auto

conditioning Power supply Refrigerant R404A

400V-3-50Hz Dew point temp. 100% Reference temperature Capacity control Liq. subc. (in condenser) Useful superheat 100%

Result

Cooling capacity COP/EER Q [W] COP[-] Qu* [W] Evaporator capacity m [kg/h] Mass flow P [kW] Power input Operating mode Op.

th [°C] I [A] Current Discharge gas temp. w/o cooling

Qc [W] Condenser capacity

tc	to	-10°C	-15°C	-20°C	-25°C	-30°C	-35°C	-40°C	-45°C
30°C	Q [W]	22309	18193	14643	11595	8992	6784	4924	3369
	Qu* [W]	22309	18193	14643	11595	8992	6784	4924	3369
	P [kW]	6,70	6,18	5,62	5,02	4,40	3,76	3,11	2,46
	I [A]	11,54	10,76	9,94	9,09	8,24	7,41	6,62	5,91
	Qc [W]	29008	24373	20262	16618	13393	10545	8034	5827
	COP [-]	3,33	2,94	2,61	2,31	2,04	1,80	1,58	1,37
	m [kg/h]	555	449	359	282	218	163,7	118,4	80,8
	Op.	Standard							
	th [°C]	76,7	83,5	90,7	98,5	107,2	116,9	128,2	0
40°C	Q [W]	18673	15142	12092	9469	7227	5324	3720	2380
	Qu* [W]	18673	15142	12092	9469	7227	5324	3720	2380
	P [kW]	7,45	6,76	6,03	5,28	4,52	3,74	2,95	2,15
	I [A]	12,68	11,62	10,54	9,46	8,40	7,38	6,44	5,61
	Qc [W]	26127	21898	18123	14753	11746	9063	6669	4532
	COP [-]	2,50	2,24	2,00	1,79	1,60	1,42	1,26	1,11
	m [kg/h]	523	420	333	259	196,4	144,0	100,2	63,9
	Op.	Standard							
	th [°C]	88,0	94,9	102,3	110,5	119,5	129,5	0	0
50°C	Q [W]	14970	12054	9533	7366	5516	3949	2635	
	Qu* [W]	14970	12054	9533	7366	5516	3949	2635	
	P [kW]	7,98	7,12	6,26	5,41	4,55	3,67	2,78	
	I [A]	13,47	12,17	10,89	9,64	8,43	7,30	6,25	
	Qc [W]	22945	19171	15796	12773	10061	7622	5417	
	COP [-]	1,88	1,69	1,52	1,36	1,21	1,08	0,95	
	m [kg/h]	485	386	303	232	172,6	122,9	81,6	
	Op.	Standard							
	th [°C]	99,5	106,6	114,5	123,3	133,4	0	0	


⁻⁻ No calculation possible (see message in single point selection)

Application Limits 100% 4VCS-6.2

1/6

^{*}According to EN12900 (20°C suction gas temp., 0K liquid subcooling)








Technical Data: (4VCS-6.2Y)

Dimensions and Connections





31.05.2023 / All data subject to change.

Technical Data

Technical Data

Displacement (1450 RPM 50Hz) 34,73 m3/h Displacement (1750 RPM 60Hz) 41,92 m3/h

No. of cylinder x bore x stroke 4 x 55 mm x 42 mm

Weight 129 kg
Max. pressure (LP/HP) 19 / 28 bar
Connection suction line 28 mm - 1 1/8"
Connection discharge line 22 mm - 7/8"

Oil type R134a/R407C/R404A/R507A/R407A/R407F tc<55°C: BSE32 | tc>55°C: BSE55 (Option)

Oil type R22 (R12/R502) B5.2 (Standard)
Oil type R290/R1270 SHC226E (Standard)

Motor data

Motor voltage (more on request) 380-420V PW-3-50Hz

Max operating current 14.0 A Winding ratio 50/50

Starting current (Rotor locked) 39.0 A Y / 68.0 A YY

Max. Power input 8,1 kW

Extent of delivery (Standard)

Motor protectionSE-B1Enclosure classIP65Vibration dampersStandardOil charge2,60 dm³

Available Options

Connection suction lineOptionDischarge shut-off valveOptionDischarge gas temperature sensorOptionStart unloadingOption

Capacity control 100-50% (Option)

Additional fan Option
CIC System Option
Oil service valve Option

Crankcase heater 0..140 W PTC (Option)

Oil level monitoring OLC-K1 (Option, not for R290/R1270)

Sound measurement

 4/6



31.05.2023 / All data subject to change

Semi-hermetic Reciprocating Compressors

Motor 1 = e.g. 4TES-12 with 12"HP", primary for air-conditioning (e.g. R22,R407C) and air-conditioning with R134a at high ambient temperatures.

Motor 2 = e.g. 4TES-9 with 8"HP", universal Motor for medium and low temperature application (e.g. R404A, R507A, R407A, R407F) and air-conditioning with R134a

Motor 3 = e.g. 4TES-8, for medium temperature applications and R134a

For more information concerning the application range use the "Limits" button.

Operation modes 4VES-7 to 6FE-44 and 44JE-30 to 66FE-88 with R407F/R407A/R22

CIC = liquid injection with low temperature application, suction gas cooled motor.

ASERCOM certified performance data

The Association of European Refrigeration Component Manufacturers has implemented a procedure of certifying performance data. The high standard of these certifications is assured by:

- * plausibility tests of the data performed by experts.
- * regular measurements at independent institutes.

These high efforts result in the fact that only a limited number of compressors can be submitted. Due to this not all BITZER compresors are certified until now. Performance data of compressors which fulfil the strict requirements may carry the label "ASERCOM certified". In this software you will find the label at the respective compressors on the right side below the field "result" or in the print out of the performance data. All certified compressors and further information are listed on the homepage of ASERCOM.

Condensing capacity

The condensing capacity can be calculated with or without heat rejection. This option can be set in the menu Program \square Options. The heat rejection is constantly 5% of the power consumption. The condensing capacity is to be found in the line Condensing cap. (with HR) resp. Condensing capacity.

Data for sound emission

Data based on 50 HZ apllication (IP-units 60 Hz) and R404A if not declared.

Sound pressure level: values based on free field area conditions with hemisperhical sound emission in 1 meter distance.

General remarks regarding sound data

Listed sound data were measured under testing conditions in our laboratory. For this purpose the free-standing test sample is mounted on a solid foundation plate and the pipework is connected vibration-free to the largest extend possible. Suction and discharge lines are fixed in a flexible configuration, such that a transmission of vibrations to the environment can be largely excluded. In real installations considerable differences might be observed, compared to the measurements in the laboratory. The airborne sound emitted by the compressor can be reflected from surfaces of the system and this may increase the airborne sound level measured close to the compressor. Vibrations caused by the compressor are also transferred to the system by the compressor feet and piping depending on the damping ratio of the fixings. Thus, the vibrations can induce other components to such an extent that these components contribute to an increase in airborne sound emission. If required, the transfer of vibrations to the system can be minimized by suitable fixing and damping elements.

Legend of connection positions according to "Dimensions":

- 1 High pressure connection (HP)
- 2 Connection for discharge gas temperature sensor (HP) (for 4VE(S)-6Y .. 4NE(S)-20(Y) connection for CIC sensor as alternative)
- 3 Low pressure connection (LP)
- 4 CIC system: injection nozzle (LP)
- 4b Connection for CIC sensor
- 4c Connection for CIC sensor (MP / operation with liquid subcooler)
- 5 Oil fill plug
- 6 Oil drain
- 7 Oil filter (magnetic screw)
- 8 Oil return (oil separator)
- 8* Oil return with NH3 and insoluble oil
- 9 Connection for oil and gas equalization (parallel operation)
- 9a Connection for gas equalization (parallel operation)

5/6



31.05.2023 / All data subject to change.

6/6

- 9b Connection for oil equalization (parallel operation)
- 10 Oil heater connection
- 11 Oil pressure connection +
- 12 Oil pressure connection -
- 13 Cooling water connection
- 14 Intermediate pressure connection (MP)
- 15 Liquid injection (operation without liquid subcooler and with thermostatic expansion valve)
- 16 Connection for oil monitoring (opto-electrical oil monitoring "OLC-K1" or differential oil pressure switch "Delta-PII")
- 17 Refrigerant inlet at liquid subcooler
- 18 Referigerant outlet at liquid subcooler
- 19 Clamp space
- 20 Terminal plate
- 21 Maintenance connection for oil valve
- 22 Pressure relief valve to the atmosphere (discharge side)
- 23 Pressure relief valve to the atmosphere (suction side)
- 24 IQ MODULE
- SL Suction gas line
- DL Discharge gas line

Dimensions can show tolerances according to EN ISO 13920-B.