25.09.2023 / All data subject to change.

Selection: Semi-hermetic Reciprocating Compressors

Input Values

Compressor model(4CC-6.F1Y)Suction gas temperature20,00 °CModeRefrigeration and AirOperating modeAuto

conditioning
Refrigerant R134a Power supply 400V-3-50Hz

Reference temperature Dew point temp. Frequency compressor 80,0 Hz
Liq. subc. (in condenser) 0 K Useful superheat 100%

Result

 Q [W]
 Cooling capacity
 COP [-]
 COP/EER

 Qu* [W]
 Evaporator capacity
 m [kg/h]
 Mass flow

 P [kW]
 Power input
 Op.
 Operating mode

 $\label{eq:localization} I\,[A] \qquad \qquad \text{Current} \qquad \qquad \text{th}\, [^\circ\text{C}] \qquad \qquad \text{Discharge gas temp. w/o cooling}$


Qc [W] Condenser capacity

tc	to	5°C	0°C	-5°C	-10°C	-15°C	-20°C	-25°C	-30°C
30°C	Q [W]		28445	23038	18428	14520	11226	8472	
	Qu* [W]		28445	23038	18428	14520	11226	8472	
	P [kW]		7,01	6,53	5,98	5,37	4,72	4,03	
	I [A]		10,91	10,22	9,44	8,58	7,64	6,62	
	Qc [W]		35456	29564	24406	19892	15946	12500	
	COP [-]		4,06	3,53	3,08	2,70	2,38	2,10	
	m [kg/h]		588	473	376	295	228	171,2	
	Op.		Standard	Standard	Standard	Standard	Standard	Standard	
	th [°C]		72,8	80,3	88,4	97,1	106,4	116,4	
40°C	Q [W]		24905	20091	15982	12492	9546	7079	
	Qu* [W]		24905	20091	15982	12492	9546	7079	
	P [kW]		8,11	7,43	6,69	5,90	5,06	4,19	
	I [A]		12,48	11,51	10,46	9,33	8,13	6,86	
	Qc [W]		33018	27525	22674	18388	14604	11265	
	COP [-]		3,07	2,70	2,39	2,12	1,89	1,69	
	m [kg/h]		562	451	356	277	211	156,1	
	Op.		Standard	Standard	Standard	Standard	Standard	Standard	
	th [°C]		84,5	92,5	101,0	110,0	119,6	129,5	
50°C	Q [W]		21507	17280	13663	10586	7984	5799	
	Qu* [W]		21507	17280	13663	10586	7984	5799	
	P [kW]		9,05	8,18	7,25	6,27	5,25	4,21	
	I [A]		13,83	12,57	11,24	9,86	8,41	6,89	
	Qc [W]		30556	25458	20912	16855	13235	10005	
	COP [-]		2,38	2,11	1,88	1,69	1,52	1,38	
	m [kg/h]		537	429	337	260	194,9	141,1	
	Op.		Standard	Standard	Standard	Standard	Standard	Standard	
	th [°C]		96,1	104,4	113,1	122,3	131,9	0	

⁻⁻ No calculation possible (see message in single point selection)

Application Limits 4CC-6.F1


25.09.2023 / All data subject to change.







Technical Data: (4CC-6.F1Y)

Dimensions and Connections







25.09.2023 / All data subject to change.

Technical Data

Tec	hnical	Data
100	ıııııca	Dala

 Displacement (1450 RPM 50Hz)
 32,48 m3/h

 Displacement (1750 RPM 60Hz)
 39,20 m3/h

 Displacement at 87 Hz
 57,4 m3/h

 Frequency range
 25..87 Hz

No. of cylinder x bore x stroke 4 x 55 mm x 39,3 mm

Weight 104,4 kg
Max. pressure (LP/HP) 19 / 28 bar
Connection suction line 35 mm - 1 3/8"
Connection discharge line 22 mm - 7/8"

Oil type R134a/R407C/R404A/R507A/R407A/R407F tc<55°C: BSE32 | tc>55°C: BSE55 (Option)

Oil type R22 (R12/R502) B5.2 (Standard)

Motor data

Electrical data frequency inverter

Voltage 380..480V/3/50_60Hz

Max operating current 22.0 A
Max. Power input 12,0 kW

Extent of delivery (Standard)

Motor protectionSE-B1Enclosure classIP65Vibration dampersStandardOil charge2,00 dm³

Available Options

Discharge gas temperature sensor Option
Additional fan Option

Crankcase heater 0..120 W PTC (Option)
Oil level monitoring OLC-K1 (Option)

Sound measurement



25.09.2023 / All data subject to change

Semi-hermetic Reciprocating Compressors

Motor 1 = e.g. 4TES-12 with 12"HP", primary for air-conditioning (e.g. R22,R407C) and air-conditioning with R134a at high ambient temperatures.

Motor 2 = e.g. 4TES-9 with 8"HP", universal Motor for medium and low temperature application (e.g. R404A, R507A, R407A, R407F) and air-conditioning with R134a

Motor 3 = e.g. 4TES-8, for medium temperature applications and R134a

For more information concerning the application range use the "Limits" button.

Operation modes 4VES-7 to 6FE-44 and 44JE-30 to 66FE-88 with R407F/R407A/R22

CIC = liquid injection with low temperature application, suction gas cooled motor.

ASERCOM certified performance data

The Association of European Refrigeration Component Manufacturers has implemented a procedure of certifying performance data. The high standard of these certifications is assured by:

- * plausibility tests of the data performed by experts.
- * regular measurements at independent institutes.

These high efforts result in the fact that only a limited number of compressors can be submitted. Due to this not all BITZER compresors are certified until now. Performance data of compressors which fulfil the strict requirements may carry the label "ASERCOM certified". In this software you will find the label at the respective compressors on the right side below the field "result" or in the print out of the performance data. All certified compressors and further information are listed on the homepage of ASERCOM.

Condensing capacity

The condensing capacity can be calculated with or without heat rejection. This option can be set in the menu Program \square Options. The heat rejection is constantly 5% of the power consumption. The condensing capacity is to be found in the line Condensing cap. (with HR) resp. Condensing capacity.

Data for sound emission

Data based on 50 HZ apllication (IP-units 60 Hz) and R404A if not declared.

Sound pressure level: values based on free field area conditions with hemisperhical sound emission in 1 meter distance.

General remarks regarding sound data

Listed sound data were measured under testing conditions in our laboratory. For this purpose the free-standing test sample is mounted on a solid foundation plate and the pipework is connected vibration-free to the largest extend possible. Suction and discharge lines are fixed in a flexible configuration, such that a transmission of vibrations to the environment can be largely excluded. In real installations considerable differences might be observed, compared to the measurements in the laboratory. The airborne sound emitted by the compressor can be reflected from surfaces of the system and this may increase the airborne sound level measured close to the compressor. Vibrations caused by the compressor are also transferred to the system by the compressor feet and piping depending on the damping ratio of the fixings. Thus, the vibrations can induce other components to such an extent that these components contribute to an increase in airborne sound emission. If required, the transfer of vibrations to the system can be minimized by suitable fixing and damping elements.

Legend of connection positions according to "Dimensions":

- 1 High pressure connection (HP)
- 2 Connection for discharge gas temperature sensor (HP) (for 4VE(S)-6Y .. 4NE(S)-20(Y) connection for CIC sensor as alternative)
- 3 Low pressure connection (LP)
- 4 CIC system: injection nozzle (LP)
- 4b Connection for CIC sensor
- 4c Connection for CIC sensor (MP / operation with liquid subcooler)
- 5 Oil fill plug
- 6 Oil drain
- 7 Oil filter (magnetic screw)
- 8 Oil return (oil separator)
- 8* Oil return with NH3 and insoluble oil
- 9 Connection for oil and gas equalization (parallel operation)
- 9a Connection for gas equalization (parallel operation)



25.09.2023 / All data subject to change.

6/6

- 9b Connection for oil equalization (parallel operation)
- 10 Oil heater connection
- 11 Oil pressure connection +
- 12 Oil pressure connection -
- 13 Cooling water connection
- 14 Intermediate pressure connection (MP)
- 15 Liquid injection (operation without liquid subcooler and with thermostatic expansion valve)
- 16 Connection for oil monitoring (opto-electrical oil monitoring "OLC-K1" or differential oil pressure switch "Delta-PII")
- 17 Refrigerant inlet at liquid subcooler
- 18 Referigerant outlet at liquid subcooler
- 19 Clamp space
- 20 Terminal plate
- 21 Maintenance connection for oil valve
- 22 Pressure relief valve to the atmosphere (discharge side)
- 23 Pressure relief valve to the atmosphere (suction side)
- 24 IQ MODULE
- SL Suction gas line
- DL Discharge gas line

Dimensions can show tolerances according to EN ISO 13920-B.