30.10.2023 / All data subject to change.

# Selection: Semi-hermetic Reciprocating Compressors

## Input Values

Compressor model 4DES-7Y Suction gas temperature 20,00 °C Mode Refrigeration and Air Operating mode Auto

conditioning

Refrigerant R404A Power supply 400V-3-50Hz
Reference temperature Dew point temp. Capacity control 100%
Liq. subc. (in condenser) 0 K Useful superheat 100%

Result

 Q [W]
 Cooling capacity
 COP [ - ]
 COP/EER

 Qu\* [W]
 Evaporator capacity
 m [kg/h]
 Mass flow

 P [kW]
 Power input
 Op.
 Operating mode

I [A] Current th [°C] Discharge gas temp. w/o cooling Qc [W] Condenser capacity

tc	to	10°C	0°C	-10°C	-20°C	-30°C	-40°C	-50°C	-60°C
30°C		10 C							
30.0	Q [W] Qu* [W]	-	25447 25447	17332 17332	11346 11346	7028 7028	4016 4016		-
	P [kW]		5,38	4,99	4,34	3,52	2,65		
	I [A]		10,00	9,52	8,73	7,84	7,03		
	Qc [W]		30823	22325	15683	10547	6664		
	COP [ - ]		4,73	3,47	2,62	2,00	1,52		
	m [kg/h]		647	431	278	170,3	96,6		
	Op.		Standard	Standard	Standard	Standard	Standard		
	th [°C]		61,6	75,1	90,5	108,7	132,0		
40°C	Q [W]		21732	14739	9573	5854	3273		
	Qu* [W]		21732	14739	9573	5854	3273		
	P [kW]		6,37	5,68	4,76	3,73	2,71		
	I [A]		11,34	10,40	9,23	8,06	7,07		
	Qc [W]		28105	20418	14336	9589	5978		
	COP [ - ]		3,41	2,60	2,01	1,57	1,21		
	m [kg/h]		623	413	263	159,1	88,2		
	Op.		Standard	Standard	Standard	Standard	Standard		
	th [°C]		72,7	86,4	102,2	120,9	0		
50°C	Q [W]		17882	12063	7756	4661	2527		
	Qu* [W]		17882	12063	7756	4661	2527		
	P [kW]		7,21	6,23	5,08	3,86	2,69		
	I [A]		12,51	11,14	9,62	8,19	7,06		
	Qc [W]		25088	18291	12831	8519	5214		
	COP [ - ]		2,48	1,94	1,53	1,21	0,94		
	m [kg/h]		596	391	246	145,8	78,3		
	Ор.		Standard	Standard	Standard	Standard	Standard		
	th [°C]		83,9	98,0	114,2	133,7	0		


<sup>--</sup> No calculation possible (see message in single point selection)

## Application Limits 100% 4DES-7

1/6

<sup>\*</sup>According to EN12900 (20°C suction gas temp., 0K liquid subcooling)








# **Technical Data: 4DES-7Y**

# **Dimensions and Connections**





30.10.2023 / All data subject to change.

**Technical Data** 

**Technical Data** 

Displacement (1450 RPM 50Hz) 26,84 m3/h Displacement (1750 RPM 60Hz) 32,39 m3/h

No. of cylinder x bore x stroke 4 x 50 mm x 39,3 mm

Weight100 kgMax. pressure (LP/HP)19 / 32barConnection suction line28 mm - 1 1/8"Connection discharge line22 mm - 7/8"

Oil type R134a/R407C/R404A/R507A/R407A/R407F BSE32(Standard) | R134a tc>70°C: BSE55 (Option)

Oil type R22 (R12/R502) B5.2 (Option)

BSE85K (Option)

Ölfüllung R454C/R455A BSE32 (Standard)

Motor data

Motor version 1

Motor voltage (more on request) 380-420V Y-3-50Hz

Max operating current 16.5 A
Starting current (Rotor locked) 82.4 A
Max. Power input 8,9 kW

Extent of delivery (Standard)

Motor protection SE-B3(Standard), SE-B2(Option)

Enclosure class IP66
Vibration dampers Standard
Oil charge 2,00 dm³
Discharge shut-off valve Standard
Suction shut-off valve Standard

**Available Options** 

Discharge gas temperature sensor Option

Capacity control 100-50% (Option)
Capacity Control - infinite 100-10% (Option)

Additional fan Option

Crankcase heater 0..120 W PTC (Option)
Oil level monitoring OLC-K1 (Option)

Sound measurement

4/6



30.10.2023 / All data subject to change.

5/6

# **Semi-hermetic Reciprocating Compressors**

**Motor 1 =** e.g. 4TES-12 with 12"HP", primary for air-conditioning (e.g. R22,R407C) and air-conditioning with R134a at high ambient temperatures.

**Motor 2 =** e.g. 4TES-9 with 8"HP", universal Motor for medium and low temperature application (e.g. R404A, R507A, R407A, R407F) and air-conditioning with R134a

Motor 3 = e.g. 4TES-8, for medium temperature applications and R134a

For more information concerning the application range use the "Limits" button.

#### Operation modes 4VES-7 to 6FE-44 and 44JE-30 to 66FE-88 with R407F/R407A/R22

CIC = liquid injection with low temperature application, suction gas cooled motor.

## ASERCOM certified performance data

The Association of European Refrigeration Component Manufacturers has implemented a procedure of certifying performance data. The high standard of these certifications is assured by:

- \* plausibility tests of the data performed by experts.
- \* regular measurements at independent institutes.

These high efforts result in the fact that only a limited number of compressors can be submitted. Due to this not all BITZER compresors are certified until now. Performance data of compressors which fulfil the strict requirements may carry the label "ASERCOM certified". In this software you will find the label at the respective compressors on the right side below the field "result" or in the print out of the performance data. All certified compressors and further information are listed on the homepage of ASERCOM.

## Condensing capacity

The condensing capacity can be calculated with or without heat rejection. This option can be set in the menu Program  $\square$  Options. The heat rejection is constantly 5% of the power consumption. The condensing capacity is to be found in the line Condensing cap. (with HR) resp. Condensing capacity.

#### Data for sound emission

Data based on 50 HZ apllication (IP-units 60 Hz) and R404A if not declared.

Sound pressure level: values based on free field area conditions with hemisperhical sound emission in 1 meter distance.

#### General remarks regarding sound data

Listed sound data were measured under testing conditions in our laboratory. For this purpose the free-standing test sample is mounted on a solid foundation plate and the pipework is connected vibration-free to the largest extend possible. Suction and discharge lines are fixed in a flexible configuration, such that a transmission of vibrations to the environment can be largely excluded. In real installations considerable differences might be observed, compared to the measurements in the laboratory. The airborne sound emitted by the compressor can be reflected from surfaces of the system and this may increase the airborne sound level measured close to the compressor. Vibrations caused by the compressor are also transferred to the system by the compressor feet and piping depending on the damping ratio of the fixings. Thus, the vibrations can induce other components to such an extent that these components contribute to an increase in airborne sound emission. If required, the transfer of vibrations to the system can be minimized by suitable fixing and damping elements.

#### Legend of connection positions according to "Dimensions":

- 1 High pressure connection (HP)
- 2 Connection for discharge gas temperature sensor (HP) (for 4VE(S)-6Y .. 4NE(S)-20(Y) connection for CIC sensor as alternative)
- 3 Low pressure connection (LP)
- 4 CIC system: injection nozzle (LP)
- 4b Connection for CIC sensor
- 4c Connection for CIC sensor (MP / operation with liquid subcooler)
- 5 Oil fill plug
- 6 Oil drain
- 7 Oil filter (magnetic screw)
- 8 Oil return (oil separator)
- 8\* Oil return with NH3 and insoluble oil
- 9 Connection for oil and gas equalization (parallel operation)
- 9a Connection for gas equalization (parallel operation)



30.10.2023 / All data subject to change.

6/6

- 9b Connection for oil equalization (parallel operation)
- 10 Oil heater connection
- 11 Oil pressure connection +
- 12 Oil pressure connection -
- 13 Cooling water connection
- 14 Intermediate pressure connection (MP)
- 15 Liquid injection (operation without liquid subcooler and with thermostatic expansion valve)
- 16 Connection for oil monitoring (opto-electrical oil monitoring "OLC-K1" or differential oil pressure switch "Delta-PII")
- 17 Refrigerant inlet at liquid subcooler
- 18 Referigerant outlet at liquid subcooler
- 19 Clamp space
- 20 Terminal plate
- 21 Maintenance connection for oil valve
- 22 Pressure relief valve to the atmosphere (discharge side)
- 23 Pressure relief valve to the atmosphere (suction side)
- 24 IQ MODULE
- SL Suction gas line
- DL Discharge gas line

Dimensions can show tolerances according to EN ISO 13920-B.