

Bitzer HSK 7461-80 dx condensing unit

Specifications

Brand	Bitzer
Туре	HSK 7461-80 dx
	condensing unit
Refrigerant	Freon
Refrigerant type	R 404 A or other types
kW at $+10^{\circ}C/+40^{\circ}C$	236,7*
kW at 0ºC/+40ºC	196,6
kW at -5ºC/+40ºC	162
kW at -10ºC/+40ºC	132,4
kW at -20ºC/+40ºC	85,8
Unloaded Start	✓
Capacity Control	✓
On steel base frame	✓
Pressure safety switches	✓
Hp/Lp/Op	
Pressure gauges	1
Hp/Lp/Op	
Liquid receiver	✓
Liquid receiver ltr.	500
Oil separator	✓
Liquid line filter drier	✓
Sight Glass	✓
Control panel	✓
Remarks	# // *Capacity based on
	+5ºC/+40ºC // 1x
	Helpman LCY 144





	offer this as complete		
	cooling solution with		
	capacity matching		
	evaporators.		
Bendanksin∥g Unit	Please note: we will only		
Sizes	6400x1350x2550 mm		
	(LxWxH)		

Description

Used Bitzer HSK 7461-80 dx condensing unit

Used Bitzer HSK 7461-80 dx condensing unit, complete with unloaded start, capacity control, pressure safety switches, pressure gauges, oil separator, liquid line filter drier, sight glass, control panel and a liquid receiver with a volume of 500 liters.

Please note: we will only offer this as complete cooling solution with capacity matching evaporators

*Why choose for HOSBV? Were not only the largest used refrigeration specialist in Europe, but also, we deliver all equipment including an extensive test, warranty and industrial cleaning. *Optional we can also perform a new paint job and arrange the logistics.











www.hosbv.com






















www.hosbv.com



VAN KEMP	PEN by		
Koudetechi Tel. +31-344-61630 Fax. +31-344-61561	niek-Tiel NL 00 Spoorstraat 14 17 4001 CN Tiel		
	T INSTALLATIE		
Installatienummer	99.0046.01		
Instanatienunnnei	1,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
Type koelinstallatie	Centraal dx-systeem		
Type koelinstallatie			
	Centraal dx-systeem		

			110		
	te				NFELDBRUCK
	HERST. NR.	3534	426 /	2 B/	AUJAHR 2002
	Fluid	zuläs: Druck PS	sige(r) Temp. TS	Volumen Liter	Druck zur Minustemp.
-		28 bar	92°C	500	bar °C
1 may 1	Pr	üfdruck PT	43.5bar	Prüfdatum	2.2002
	Herstelle	GÜNTNER T H-2890 Szer	ATA Kft. nódi u.4.	Zusatzschild	ja nein
	Herstelle	H-2890 Szor	nódi u.4.	Zusatzschild	[ja] nein]